

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 632/D/SWA/NSA

Dated: 30/8/2025

It is certified that an inspection team headed by Alka Singh - Chemist

(Name of Officers with designation) from KANPUR NAGAR NIGAM PHED

inspected the KINGSTON EDUCATION CENTRE, 406-A, D.H.PURWA, JAJMAU KANPUR

(Name & Address of the school) on 20/08/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 393/SWA/CHEM dated 20/08/2025

of PUBLIC HEALTH LABORATORY, K.N.N. (PHED Lab) certified that the


KINGSTON EDUCATION CENTRE (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the


Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal: 
Name: Alka Singh
Designation: स्वास्थ्य अधिकारी
Name & Address of the Office / Department: PHED, KANPUR

To Kingston Education Centre
406-A, D.H.Purwa, Jajmau, Kanpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Kingston Education Centre

Principal

Kingston Education Centre
Jitendra Tiwari
Manager



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the	MS KINGSTON EDUCATION CENTRE 406-A		
Sample taken from	'SUSMERGIBLE' Ompuswa Pokharpur Jajmau, Kanpur		
Date of sample Drawn	20/8/2025		
Date of analysis	20/8/2025		
Physical Character	TRANSPARENT / ODOURLESS		
P. H. Value	6.74		
Free Ammonia Parts per 1000000	N/A		
Albuminoid Ammonia Part per 1000000	N/A		
Oxygen absorbed from pot. Permagnate in three hours at 37 C	0.00		
Chloride Part per 1000000	0.00		
Nitrates Parts per 1000000	NIL		
Nitrates Parts per 1000000	NIL		
Total solid part per 100000	240.00		
Fixed solid Parts per 1000000	210.00		
Volatils solid Parts per 100000	30.00		
Appearance on ignition	NO CHARRING		
Total hardness Parts per 1000000	96.00		
Permanent hardness Parts per 1000000	80.00		
Temporary hardness Parts per 1000000	16.00		

K.N.N. PRESS

Remarks :

POTABLE

Kingston Education Centre

[Signature]
Principal

No. 393/2025 dated 20/8/2025

Copy forwarded for favour or information to

Kingston Education Centre

Jitendra Tiwari

Manager

D 413
Kingston Education Centre
406-A, Ompuswa Pokharpur
Jajmau, Kanpur.

Nagar Swasthya Adhikari
Nagar Nigam Kanpur

ALKA SINGH
(Chemist)

नगर निगम कानपुर

112.A. Kanpur Nagar Nigam

D. No.:- 393/SOAH/Chem 20/01/2025



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from KINGSTON EDUCATION CENTRE, 406-A, Omputwada
 Name & designation of the person collecting samples... ALKA SINGH, CHEMIST
Pokhaspur, Jainpur, Kanpur

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count			Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37.c in 48 hours	at room temp- return in 72 hours	Quantity of water put in each tube No of tubes put up	50ML. 1	10 ML. 5			
20/01/2025	Submersible	ZERO	'06'	---	NIL	'1'	ZERO	NIL	'GOOD'

Copy for Information Forwarded to (1) 415 Kingston Education Centre, Jainpur Kanpur

(2) N-S.A. Kanpur Nagar Nigam

Kingston Education Centre

Jitendra Tiwari
Principal

Kingston Education Centre

Jitendra Tiwari

Manager

ALKA SINGH
(Chemist)
Nagar Nigam Kanpur